



# 2014 Drinking Water Quality Report

## **RRA - GUTHRIE-DUMONT WATER SYSTEM**

**Red River Authority of Texas**

P. O. Box 240

Wichita Falls, Texas 76307-0240

(866) 723-8697

### **OUR DRINKING WATER MEETS OR EXCEEDS ALL FEDERAL (EPA) DRINKING WATER REQUIREMENTS**

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

#### **Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800) 426-4791.

#### **En Español**

Este informe incluye información importante sobre el agua potable. Si tiene preguntas o comentarios sobre éste informe en español, favor de llamar al tel. (866) 723-8697 para hablar con una persona bilingüe en español.

#### **WHERE DO WE GET OUR DRINKING WATER?**

The **RRA-Guthrie-Dumont Water System** utilizes ground water from the Permian formation. The ground water is produced through Authority owned wells located in Dickens County, Texas. The Texas Commission on Environmental Quality (TCEQ) has completed and provided the Authority a Source Water Susceptibility Assessment for the drinking water source(s) that we own as well as for the system(s) from which we purchase water. This report describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. For more information on source water assessments and protection efforts for our system contact Henry C. Wied at (866) 723-8697.

#### **ALL DRINKING WATER MAY CONTAIN CONTAMINANTS**

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at (800) 426-4791.

## **PUBLIC PARTICIPATION OPPORTUNITIES**

The Authority's Board of Directors regularly meets on the third Wednesday of January, April, July, and September of each year. Specific times and locations of these and/or any special meetings can be obtained by contacting the Authority at (866) 723-8697.

For more information about the water quality of your water system, public participation programs, water conservation programs, and/or general operations policies, call (866) 723-8697 or e-mail the Authority at: info@rra.dst.tx.us. For service requests or reporting leaks after normal business hours, contact your District Manager, Mr. Mike Carlson at (940) 636-8064.

## **SYSTEM INFORMATION**

The Red River Authority of Texas owns and operates 29 registered public water supply systems through its Utility Division. The Utility Division maintains over 2,200 miles of transmission lines, two surface water treatment plants, 42 pumping facilities, and serves approximately 10,000 customers residing in a 15 county area of the Red River Basin. The Utility Division is subdivided into geographical districts for proper management, maintenance, and financial accounting of individual systems.

The **RRA-Guthrie-Dumont Water System** is one of the water systems operated by the Utility Division's District 15. In 2014, the system served 132 active connections with an average water use of 356 gallons per day per connection. In the water loss audit submitted to the Texas Water Development Board for the time period of January - December 2014, the system lost an estimated 16 MG of water. The primary use of the water was rural domestic. No major capital improvement items were scheduled for 2014.

The Authority maintains a Water Conservation and Drought Contingency Plan for the Utility Division. Information on the plan is available on the Authority's web page at [www.rra.dst.tx.us](http://www.rra.dst.tx.us) or can be obtained by calling (866) 723-8697.

## **DEFINITIONS:**

### **Maximum Contaminant Level (MCL) -**

The highest level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

### **Maximum Contaminant Level Goal (MCLG) -**

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

**Organic Contaminants** - TESTING WAIVED, NOT REPORTED, OR NONE DETECTED

**Fecal Coliform** - REPORTED MONTHLY TESTS FOUND NO FECAL COLIFORM BACTERIA.

**Total Coliform** - REPORTED MONTHLY TESTS FOUND NO COLIFORM BACTERIA.

**Unregulated Initial Distribution System Evaluation for Disinfection Byproducts** - WAIVED OR NOT YET SAMPLED

### **Maximum Residual Disinfectant Level (MRDL) -**

The highest level of disinfectant allowed in drinking water.

There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

### **Maximum Residual Disinfectant Level Goal (MRDLG) -**

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

### **Treatment Technique (TT) -**

A required process intended to reduce the level of a contaminant in drinking water.

### **Action Level (AL) -**

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**NTU** - Nephelometric Turbidity Units

**MFL** - million fibers per liter

**pCi/L** - picocuries per liter (a measure of radioactivity)

**ppm** - parts per million, or milligrams per liter (mg/l)

**ppb** - parts per billion, or micrograms per liter (ug/l)

**ppt** - parts per trillion, or nanograms per liter

**MG** - million gallons

## **SECONDARY CONSTITUENTS**

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concerns. Therefore, secondary constituents are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

## **Additional Health Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## **ABOUT THE FOLLOWING TABLES**

U.S. EPA requires water systems to test up to 97 constituents. The attached table contains all of the federally regulated or monitored constituents which have been found in your drinking water.

### Inorganic Contaminants

		Highest	Range of			Unit of		
2014	Arsenic	3.99	3.99 - 3.99	0	10	ppb	N	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics
2014	Barium	0.0386	0.0386 -	2	2	ppm	N	Discharge of drilling wastes; Discharge from
2012	Fluoride	0.15	0.15 - 0.15	4	4	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from
2014	Nitrate	15	14.3 - 14.6	10	10	ppm	Y	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural depos-
2014	Selenium	19.9	19.9 - 19.9	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge

### Radioactive Contaminants

Year	Contaminant	Highest Level	Range of Levels	MCLG	MCL	Unit of Measure	Violation	Source of Contaminant
2010	Gross Beta Emitters	4	4.0 - 4.0	0	50	pCi/L	N	Decay of natural and man-made deposits.

### Disinfection Byproducts

Year	Contaminant	Highest Level	Range of Levels	MCLG	MCL	Unit of Measure	Violation	Source of Contaminant
2011	Haloacetic Acids (HAA5)	4.6	4.6 - 4.6	No goal for the total	60	ppb	N	Byproduct of drinking water disinfection.
2011	Total Trihalomethanes (TTHM)	16.6	16.6 - 16.6	No goal for the total	80	ppb	N	Byproduct of drinking water disinfection.

### Maximum Residual Disinfectant Level

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Unit of Measure	Source of Chemical
2014	Chlorine	0.94	0.55	1.44	4.0	< 4.0	ppm	Disinfectant used to control microbes.

**Red River Authority of Texas**  
**P. O. Box 240**  
**Wichita Falls, Texas 76307-0240**

FIRST CLASS MAIL  
 U.S. POSTAGE PAID  
 WICHITA FALLS TX  
 PERMIT 212

**RETURN SERVICE REQUESTED**

**Lead and Copper**

Year	Contaminant	MCLG	Action Level	90th Percentile	# of Sites Over AL	Unit of Measure	Violation	Source of Contaminant
2013	Copper	1.3	1.3	0.139	0	ppm	N	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
2013	Lead	0	15	2.8	0	ppb	N	Corrosion of household plumbing systems; Erosion of natural deposits.

**Violations**

<b>Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and , if untreated, may die. Symptoms include shortness of breath and blue-baby syndrome.</b>			
Violation Type	Violation Begin	Violation End	Explanation
MCL, Nitrate Single Sample	01/01/2014	03/31/2014	A water sample showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated.
MCL, Nitrate Single Sample	04/01/2014	06/30/2015	A water sample showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated.
MCL, Nitrate Single Sample	07/01/2014	09/30/2015	A water sample showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated.
MCL, Nitrate Single Sample	10/01/2014	12/31/2015	A water sample showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated.