



2004 Drinking Water Quality Report

RRA - HOWARDWICK WATER SYSTEM

Red River Authority of Texas

900 8th Street, Suite 520

Wichita Falls, Texas 76301

OUR DRINKING WATER MEETS OR EXCEEDS ALL FEDERAL (EPA) DRINKING WATER REQUIREMENTS

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

Special Notice for the ELDERLY, INFANTS, CANCER PATIENTS, people with HIV/AIDS or other immune problems:

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control and Prevention (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline at (800) 426-4791.

En Espanol

Este reporte incluye informacion importante sobre el agua para tomar. Si tiene preguntas o' discusiones sobre este reporte en espanol, favor de llamar al tel. (940) 723-8697 par hablar con una persona bilingue en espanol.

WHERE DO WE GET OUR DRINKING WATER?

The **RRA-Howardwick Water System** utilizes ground water from the Ogallala aquifer. The ground water is produced through Authority owned wells located in Donley County, Texas. The Texas Commission on Environmental Quality (TCEQ) has completed a Source Water Susceptibility Assessment for your drinking water source(s). This report describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in this assessment will allow us to focus our source water protection activities. For more information on source water assessments and protection efforts for our system contact Henry C. Wied at (940) 723-8697.

ALL DRINKING WATER MAY CONTAIN CONTAMINANTS

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800) 426-4791.

PUBLIC PARTICIPATION OPPORTUNITIES

The Authority's Board of Directors regularly meets on the third Wednesday of January, April, July, and September of each year. Specific times and locations of these and/or any special meetings can be obtained by contacting the Authority at (940) 723-8697.

For more information about the water quality of your water system, public participation programs, water conservation programs, and/or general operations policies, call (940) 723-8697 or e-mail the Authority at: info@rra.dst.tx.us. For service requests or reporting leaks after normal business hours, contact your District Manager, Mr. Walt Rice at (806) 664-8385 or Mr. Jerry Cadena at (940) 937-0847.

SYSTEM INFORMATION

The Red River Authority of Texas owns and operates 29 registered public water supply systems through its Utility Division. The Utility Division maintains over 2,150 miles of transmission lines, two surface water treatment plants, 65 pumping facilities and serves approximately 10,000 customers residing in a 15 county area of the Red River Basin. The Utility Division is subdivided into geographical districts for proper management, maintenance, and financial accounting of individual systems.

The **RRA-Howardwick Water System** is one of the water systems operated by the Utility Division's District 18. In 2004, the system served 380 active connections with an average water use of 203 gallons per day per connection. The primary use of the water was seasonal and rural

domestic. No major capital improvement items were scheduled for 2004.

The Authority maintains a Water Conservation and Drought Contingency Plan for the Utility Division. Information on the plan is available on the Authority's web page at www.rra.dst.tx.us or can be obtained by calling (940) 723-8697.

DEFINITIONS:

Maximum Contaminant Level (MCL) –

The highest level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) –

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

Treatment Technique (TT) –

A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL) –

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

NTU – Nephelometric Turbidity Units

MFL – million fibers per liter

pCi/l – picocuries per liter (a measure of radioactivity)

ppm – parts per million, or milligrams per liter (mg/l)

ppb – parts per billion, or micrograms per liter (ug/l)

ppt – parts per trillion, or nanograms per liter

ppq – parts per quadrillion, or picograms per liter

SECONDARY CONSTITUENTS

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of Texas, not the EPA. These constituents are not causes for health concerns. Therefore, secondaries are not required to be reported in this document, but they may greatly affect the appearance and taste of your water.

ABOUT THE FOLLOWING TABLES

U.S. EPA requires water systems to test up to 97 constituents. The attached table contains all of the federally regulated or monitored constituents which have been found in your drinking water.

Inorganic Contaminants

Year (Range)	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2004-2004	Barium	0.048	0.0479	0.0479	2	2	ppm	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
2003-2003	Fluoride	1.000	1	1	4	4	ppm	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
2004-2004	Nitrate	7.450	7.45	7.45	10	10	ppm	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
2004-2004	Selenium	11.600	11.6	11.6	50	50	ppb	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.
2004-2004	Uranium	19.000	19	19	30	0	ppb	Erosion of natural deposits.
2004-2004	Combined Radium 226 & 228	0.100	0.1	0.1	5	0	pCi/L	Erosion of natural deposits.
2004-2004	Gross alpha adjusted	6.500	6.5	6.5	15	0	pCi/L	Erosion of natural deposits.
2004-2004	Gross beta emitters	11.400	11.4	11.4	50	0	pCi/L	Decay of natural and manmade deposits.

Unregulated Contaminants

Year (Range)	Contaminant	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant
2002-2002	Chloroform	0.350	0	0.7	ppb	Byproduct of drinking water disinfection.
2002-2002	Bromoform	2.700	2.3	3.1	ppb	Byproduct of drinking water disinfection.
2002-2002	Bromodichloromethane	1.700	1.6	1.8	ppb	Byproduct of drinking water disinfection.
2002-2002	Dibromochloromethane	3.1500	3.1	3.2	ppb	Byproduct of drinking water disinfection.

Disinfection Byproducts

Year	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Contaminant
2004-2004	Total Haloacetic Acids	7.400	7.4	7.4	60	ppb	Byproduct of drinking water disinfection.
2004-2004	Total Trihalomethanes	7.800	7.8	7.8	80	ppb	Byproduct of drinking water disinfection.

Red River Authority of Texas
 Hamilton Building
 900 8th Street, Suite 520
 Wichita Falls, Texas 76301-6894

PRSRT STD
 U.S. POSTAGE PAID
 WICHITA FALLS TX
 PERMIT NO. 212

RETURN SERVICE REQUESTED

Maximum Residual Disinfectant Level

Year (Range)	Disinfectant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2004	Chlorine	1.482	0.8	1.8	4	4	ppm	Disinfectant used to control microbes.

Lead and Copper

Year (Range)	Contaminant	The 90 th Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Contaminant
2002-2002	Copper	0.0810	0	1.3	ppm	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives.
2002-2002	Lead	2.9000	0	15	ppb	Corrosion of household plumbing systems; Erosion of natural deposits.

Organic Contaminants - NOT TESTED OR REPORTED, OR NONE DETECTED

Total Coliform - NOT DETECTED

Fecal Coliform - NOT DETECTED

Turbidity - NOT REQUIRED